



STREET ADDRESS

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184

MAILING ADDRESS

P.O. Box 1049
Columbus, OH 43216-1049

March 19, 2004

RE: Medina County
Foundation Software, Inc.
Non-Transient, Non-Community
PWSID#: 5253412

Ms. Carolyn Ermlick, Director of Administration
Foundation Software, Incorporated
150 Pearl Road
Brunswick, Ohio 44212

Dear Ms. Ermlick:

The Foundation Software, Inc.'s public water system has violated Ohio's safe drinking water laws. Specifically, Foundation Software, Inc. exceeded the maximum contaminant level (MCL) for total coliform bacteria, failed to conduct routine total coliform bacteria monitoring, failed to conduct repeat total coliform bacteria monitoring, failed to conduct synthetic organic chemical (SOC) monitoring, and failed to issue public notices.

Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.


To resolve your drinking water violations and avoid possible legal action and civil penalties:

- 1) Comply with total coliform monitoring and MCL requirements, in accordance with Ohio Administrative Code (OAC) Rules 3745-81-14 and 3745-81-21.
- 2) On or before April 15, 2004, initiate an investigation, by hiring a licensed plumber, on the interior plumbing to determine possible causes of the bacteriological contamination. Within thirty days of initiation, submit a written report of findings and recommendations to the Ohio Environmental Protection Agency (Ohio EPA), Northeast District Office (NEDO), Division of Drinking and Ground Waters (DDAGW), Attn: Ken Ristow, 2110 E. Aurora Road, Twinsburg, Ohio 44087.
- 3) Post public notification for total coliform bacteria monitoring and MCL violations in accordance with OAC Rule 3745-81-32. Send the public notices and verification forms to Ohio EPA, NEDO, DDAGW by March 31, 2004
- 4) Comply with the monitoring and reporting requirements in accordance with the 2004 chemical monitoring entry point schedule and the 2004 chemical monitoring distribution schedule.

Bob Taft, Governor
Jennette Bradley, Lieutenant Governor
Christopher Jones, Director

04 APR - 1 AM 10:30
RECEIVED
DDAGW

Sincerely,



for Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Larry Reeder at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Larry Reeder at (614) 644-2752.



Ms. Carolyn Ermlick, Director
Foundation Software, Incorporated

Date

3/29/04