



State of Ohio Environmental Protection Agency

## CONDITIONAL LICENSE TO OPERATE OR MAINTAIN A PUBLIC WATER SYSTEM

THE OHIO EPA, PURSUANT TO SECTION 6109.21 OF THE OHIO REVISED CODE, HEREBY ISSUES THIS  
LICENSE TO OPERATE OR MAINTAIN A PUBLIC WATER SYSTEM TO

**HINEYS SALOON PWS**

**PWS ID: OH8039612**

THE LICENSEE IS OBLIGATED TO ENSURE THAT THE PUBLIC WATER SYSTEM IS OPERATED AND  
MAINTAINED IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 6109 OF THE OHIO REVISED  
CODE, ALL OTHER APPLICABLE STATUTES AND THE ADMINISTRATIVE RULES ADOPTED THEREUNDER.

**THIS LICENSE WILL EXPIRE ON JANUARY 30, 2011**

APPLICATION FOR RENEWAL IS REQUIRED TO BE SUBMITTED TO THE OHIO EPA AT LEAST THIRTY  
DAYS PRIOR TO THIS DATE.

EFFECTIVE DATE: **JANUARY 1, 2010**

EXPIRATION DATE: **JANUARY 30, 2011**

LICENSE NUMBER: **8039612-732467-2010**

A handwritten signature in cursive script, appearing to read "Chris Kozel".

Director

## V. ORDERS

1. From the effective date of these Orders, the LTO renewal for Respondent's PWS is issued with the conditions listed in Orders # 2 through 6, for the period of January 31, 2010 to January 30, 2011, in accordance with OAC Rule 3745-84-06.
2. From the effective date of these Orders, Respondent shall prominently display the conditioned LTO, in accordance with OAC Rule 3745-84-04(D).
3. From the effective date of these Orders, Respondent shall comply with all current and subsequent chemical monitoring schedules issued by the Director in accordance with OAC Chapter 3745-81. Specifically, Respondent shall monitor for nitrate with one sample collected between June 1 and October 31, 2010.
4. From the effective date of these Orders, Respondent shall comply with total coliform bacteria monitoring requirements, including both routine and repeat samples, and respond to any positive total coliform sample appropriately, in accordance with OAC Rule 3745-81-21. Specifically, at a minimum, Respondent shall monitor for total coliform bacteria with one routine sample collected each quarter.
5. Within fourteen (14) days of the effective date of these Orders, Respondent shall issue public notice, in accordance with OAC Rule 3745-81-32, for the violation listed in Finding # 8. Respondent shall provide Ohio EPA with copies of all public notice and verification forms at the address listed in Section X of these Orders.
6. Within thirty (30) days of the effective date of these Orders, Respondent shall submit the \$169.62 fee for the plan approval application for a new water source (new well), in accordance with OAC Rule 3745-91-02(B), to Ohio Environmental Protection Agency, Central District Office – DDAGW, Lazarus Government Building, P.O. Box 1049, Columbus, Ohio 43216-1049, Attn: Susan Hampton.