



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

RE: Madison County
Sunoco #6160
Transient, Non-Community
PWSID#: 4935312

Srinivas Guntupatti
Sunoco #6160
935 US Rt. 42 NE
London, Ohio 43140

Dear Mr. Guntupatti:

Hand Delivery

The Sunoco #6160 public water system has violated Ohio's safe drinking water laws. Specifically, Sunoco #6160 failed to conduct routine total coliform bacteria monitoring, failed to monitor for nitrate, and failed to issue public notices for any of these violations.


Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.

To resolve your drinking water violations and avoid possible legal action and civil penalties:

- 1) Monitor for total coliform bacteria with a minimum of one routine sample per calendar quarter from the distribution system and perform any required repeat monitoring, in accordance with Ohio Administrative Code (OAC) Rule 3745-81-21.
- 2) Monitor annually for nitrate with a minimum of one routine sample per calendar year during the July through December monitoring period in accordance with Ohio Administrative Code (OAC) Rule 3745-81-23 and your chemical monitoring schedule.
- 3) By December 31, 2004, post public notices for past total coliform and nitrate monitoring violations for at least fourteen (14) days in accordance with OAC Rule 3745-81-32. Send the public notices and verification forms to Ohio Environmental Protection Agency (EPA), Central District Office, Division of Drinking and Ground Waters, Attn: Susan Hampton, 3232 Alum Creek Drive, Columbus, Ohio 43202.
- 4) By December 31, 2004, develop a written total coliform sample siting plan and submit a copy to Ohio EPA, CDO, DDAGW, in accordance with OAC Rule 3745-81-21.


Bob Taft, Governor
Jennette Bradley, Lieutenant Governor
Christopher Jones, Director

Sincerely,



Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Emily Cushman at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Emily Cushman at (614) 644-2752.



Mr. Srinivas Guntupatti
Sunoco #6160

12/6/04

Date

Sincerely,



Emily E. Cushman
Environmental Specialist

Enclosure