



OH2600011 ARCHBOLD VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 2654219 SMP ID: EP001	Facility Name: ARCHBOLD VILLAGE Facility Source: Surface Water	Facility Class: CLASS 4
--------------------------	---	---	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements		
DIOXIN - 2063	Not Required		
INORGANICS	1 Sample(s) Required between	1/1/2021 and	5/31/2021
<i>Sample for all the analytes listed below:</i>			
ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085			
NITRITE - 1041	Not Required		
NITRATE - 1040	1 Sample(s) Required between	1/1/2021 and	1/31/2021
	1 Sample(s) Required between	2/1/2021 and	2/28/2021
	1 Sample(s) Required between	3/1/2021 and	3/31/2021
	1 Sample(s) Required between	4/1/2021 and	4/30/2021
	1 Sample(s) Required between	5/1/2021 and	5/31/2021
	1 Sample(s) Required between	6/1/2021 and	6/30/2021
	1 Sample(s) Required between	7/1/2021 and	7/31/2021
	1 Sample(s) Required between	8/1/2021 and	8/31/2021
	1 Sample(s) Required between	9/1/2021 and	9/30/2021
	1 Sample(s) Required between	10/1/2021 and	10/31/2021
	1 Sample(s) Required between	11/1/2021 and	11/30/2021
	1 Sample(s) Required between	12/1/2021 and	12/31/2021
RADIOLOGICALS	Not Required		
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between	4/1/2021 and	6/30/2021
<i>Sample for all the analytes listed below:</i>			
ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037			
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between	1/1/2021 and	5/31/2021
TOTAL ORGANIC CARBON (TOC)	1 Paired Sample Set Required between	1/1/2021 and	1/31/2021
	1 Paired Sample Set Required between	2/1/2021 and	2/28/2021
	1 Paired Sample Set Required between	3/1/2021 and	3/31/2021
	1 Paired Sample Set Required between	4/1/2021 and	4/30/2021
	1 Paired Sample Set Required between	5/1/2021 and	5/31/2021
	1 Paired Sample Set Required between	6/1/2021 and	6/30/2021
	1 Paired Sample Set Required between	7/1/2021 and	7/31/2021
	1 Paired Sample Set Required between	8/1/2021 and	8/31/2021
	1 Paired Sample Set Required between	9/1/2021 and	9/30/2021
	1 Paired Sample Set Required between	10/1/2021 and	10/31/2021
	1 Paired Sample Set Required between	11/1/2021 and	11/30/2021
	1 Paired Sample Set Required between	12/1/2021 and	12/31/2021

A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.



Effective Date: 01/01/2021

2021 ENTRY POINT SCHEDULE

OH2600011 ARCHBOLD VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2654219	Facility Name: ARCHBOLD VILLAGE	
Location	SMP ID: EP001/LT2001	Facility Source: Surface Water	Facility Class: CLASS 4

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements
------------------	--------------------------------

TOTAL MICROCYSTINS	1 Sample Set Required WEEKLY*
--------------------	-------------------------------

Total microcystins sample set refers to one raw source water sample at LT2001 and one finished water sample at EP001. A week is defined as Sunday through Saturday.

**Weekly sampling unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at <http://epa.ohio.gov/ddagw/HAB.aspx>. Reduced monitoring is contingent on a public water system continuing to experience NO raw or finished water total microcystins detections. Any total microcystins detections during routine (weekly) or reduced sampling will trigger additional sampling. Please refer to the website above for specifics on follow-up sampling requirements.*



OH2600011 ARCHBOLD VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2654219	Facility Name: ARCHBOLD VILLAGE	
Location	SMP ID: LT2001	Facility Source: Surface Water	Facility Class: CLASS 4

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

Chemicals	Monitoring Requirements
CYANOBACTERIA SCREENING	1 Sample(s) Required between 12/27/2020 and 1/2/2021
	1 Sample(s) Required between 1/10/2021 and 1/16/2021
	1 Sample(s) Required between 1/24/2021 and 1/30/2021
	1 Sample(s) Required between 2/7/2021 and 2/13/2021
	1 Sample(s) Required between 2/21/2021 and 2/27/2021
	1 Sample(s) Required between 3/7/2021 and 3/13/2021
	1 Sample(s) Required between 3/21/2021 and 3/27/2021
	1 Sample(s) Required between 4/4/2021 and 4/10/2021
	1 Sample(s) Required between 4/18/2021 and 4/24/2021
	1 Sample(s) Required between 5/2/2021 and 5/8/2021
	1 Sample(s) Required between 5/16/2021 and 5/22/2021
	1 Sample(s) Required between 5/30/2021 and 6/5/2021
	1 Sample(s) Required between 6/13/2021 and 6/19/2021
	1 Sample(s) Required between 6/27/2021 and 7/3/2021
	1 Sample(s) Required between 7/11/2021 and 7/17/2021
	1 Sample(s) Required between 7/25/2021 and 7/31/2021
	1 Sample(s) Required between 8/8/2021 and 8/14/2021
	1 Sample(s) Required between 8/22/2021 and 8/28/2021
	1 Sample(s) Required between 9/5/2021 and 9/11/2021
	1 Sample(s) Required between 9/19/2021 and 9/25/2021
1 Sample(s) Required between 10/3/2021 and 10/9/2021	
1 Sample(s) Required between 10/17/2021 and 10/23/2021	
1 Sample(s) Required between 10/31/2021 and 11/6/2021	
1 Sample(s) Required between 11/14/2021 and 11/20/2021	
1 Sample(s) Required between 11/28/2021 and 12/4/2021	
1 Sample(s) Required between 12/12/2021 and 12/18/2021	

Cyanobacteria screening sample is to be collected biweekly from raw source water at sample point LT2001 unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at <http://epa.ohio.gov/ddagw/HAB.aspx>. As of 12/31/17, all public water systems are responsible for contracting with a lab certified to perform cyanobacteria screening (qPCR). Please review the website for further information pertaining to follow-up sampling requirements for cyanobacteria screening gene detections, and certified labs that can perform analysis.



OH2600011 ARCHBOLD VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1 Facility Name: ARCHBOLD VILLAGE DISTRIBUTION SYSTEM Facility Class: CLASS 1
Location SMP ID: DS000

Chemicals Monitoring Requirements

ASBESTOS - 1094 Not Required

TOTAL COLIFORM (TCR) - 3100 6 Sample(s) Required between 1/1/2021 and 1/31/2021
6 Sample(s) Required between 2/1/2021 and 2/28/2021
6 Sample(s) Required between 3/1/2021 and 3/31/2021
6 Sample(s) Required between 4/1/2021 and 4/30/2021
6 Sample(s) Required between 5/1/2021 and 5/31/2021
6 Sample(s) Required between 6/1/2021 and 6/30/2021
6 Sample(s) Required between 7/1/2021 and 7/31/2021
6 Sample(s) Required between 8/1/2021 and 8/31/2021
6 Sample(s) Required between 9/1/2021 and 9/30/2021
6 Sample(s) Required between 10/1/2021 and 10/31/2021
6 Sample(s) Required between 11/1/2021 and 11/30/2021
6 Sample(s) Required between 12/1/2021 and 12/31/2021

TOTAL CHLORINE - 1000 6 Sample(s) Required between 1/1/2021 and 1/31/2021
6 Sample(s) Required between 2/1/2021 and 2/28/2021
6 Sample(s) Required between 3/1/2021 and 3/31/2021
6 Sample(s) Required between 4/1/2021 and 4/30/2021
6 Sample(s) Required between 5/1/2021 and 5/31/2021
6 Sample(s) Required between 6/1/2021 and 6/30/2021
6 Sample(s) Required between 7/1/2021 and 7/31/2021
6 Sample(s) Required between 8/1/2021 and 8/31/2021
6 Sample(s) Required between 9/1/2021 and 9/30/2021
6 Sample(s) Required between 10/1/2021 and 10/31/2021
6 Sample(s) Required between 11/1/2021 and 11/30/2021
6 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Facility ID: DS1 Facility Name: ARCHBOLD VILLAGE DISTRIBUTION SYSTEM Facility Class: CLASS 1
Location SMP ID: DS201 22881 MONROE ST

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 1/8/2021 and 1/14/2021 at: DS201
Dual Sample Required between 4/8/2021 and 4/14/2021 at: DS201
Dual Sample Required between 7/8/2021 and 7/14/2021 at: DS201

**OH2600011 ARCHBOLD VILLAGE**

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1	Facility Name: ARCHBOLD VILLAGE DISTRIBUTION SYSTEM	Facility Class: CLASS 1
	SMP ID: DS201	22881 MONROE ST	

Chemicals**Monitoring Requirements**

DISINFECTION BYPRODUCTS

Dual Sample Required between 10/8/2021 and 10/14/2021 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1	Facility Name: ARCHBOLD VILLAGE DISTRIBUTION SYSTEM	Facility Class: CLASS 1
	SMP ID: DS202	393 MAIN ST	

Chemicals**Monitoring Requirements**

DISINFECTION BYPRODUCTS

Dual Sample Required between 1/8/2021 and 1/14/2021 at: DS202

Dual Sample Required between 4/8/2021 and 4/14/2021 at: DS202

Dual Sample Required between 7/8/2021 and 7/14/2021 at: DS202

Dual Sample Required between 10/8/2021 and 10/14/2021 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1	Facility Name: ARCHBOLD VILLAGE DISTRIBUTION SYSTEM	Facility Class: CLASS 1
	SMP ID: LC###	Refer to your Lead and Copper plan for SMP IDs	

Chemicals**Monitoring Requirements**

LEAD - 1030 AND COPPER - 1022

20 Sample(s) Required between 6/1/2021 and 9/30/2021

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.

Sampling Location	Facility ID: DS1	Facility Name: ARCHBOLD VILLAGE DISTRIBUTION SYSTEM	Facility Class: CLASS 1
	SMP ID: MM001	3151 CO RD 2425 AT THE ELEVATED TOWER	

Chemicals**Monitoring Requirements**

DISINFECTION BYPRODUCTS

1 Sample(s) Required between 7/8/2021 and 7/14/2021 at: MM001

1 Sample(s) Required between 10/8/2021 and 10/14/2021 at: MM001



OH2600111 WAUSEON CITY

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 2654220 SMP ID: EP001	Facility Name: WAUSEON CITY Facility Source: Surface Water	Facility Class: CLASS 3
--------------------------	---	---	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements
------------------	--------------------------------

INORGANICS	1 Sample(s) Required between 1/1/2021 and 5/31/2021
------------	---

Sample for all the analytes listed below:

ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020
 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085

NITRITE - 1041	Not Required
----------------	--------------

NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 1/31/2021
	1 Sample(s) Required between 2/1/2021 and 2/28/2021
	1 Sample(s) Required between 3/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021
	1 Sample(s) Required between 11/1/2021 and 11/30/2021
	1 Sample(s) Required between 12/1/2021 and 12/31/2021

RADIOLOGICALS	Not Required
---------------	--------------

SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between 4/1/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021

Sample for all the analytes listed below:

ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037

VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 7/1/2021 and 9/30/2021
----------------------------------	---

TOTAL ORGANIC CARBON (TOC)	1 Paired Sample Set Required between 1/1/2021 and 1/31/2021
	1 Paired Sample Set Required between 2/1/2021 and 2/28/2021
	1 Paired Sample Set Required between 3/1/2021 and 3/31/2021
	1 Paired Sample Set Required between 4/1/2021 and 4/30/2021
	1 Paired Sample Set Required between 5/1/2021 and 5/31/2021
	1 Paired Sample Set Required between 6/1/2021 and 6/30/2021
	1 Paired Sample Set Required between 7/1/2021 and 7/31/2021
	1 Paired Sample Set Required between 8/1/2021 and 8/31/2021
	1 Paired Sample Set Required between 9/1/2021 and 9/30/2021
	1 Paired Sample Set Required between 10/1/2021 and 10/31/2021
	1 Paired Sample Set Required between 11/1/2021 and 11/30/2021
	1 Paired Sample Set Required between 12/1/2021 and 12/31/2021

A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.



Effective Date: 01/01/2021

2021 ENTRY POINT SCHEDULE

OH2600111 WAUSEON CITY

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2654220	Facility Name: WAUSEON CITY	
Location	SMP ID: EP001/LT2001	Facility Source: Surface Water	Facility Class: CLASS 3

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

Chemicals

Monitoring Requirements

TOTAL MICROCYSTINS

1 Sample Set Required WEEKLY*

Total microcystins sample set refers to one raw source water sample at LT2001 and one finished water sample at EP001. A week is defined as Sunday through Saturday.

*Weekly sampling unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at http://epa.ohio.gov/ddagw/HAB.aspx. Reduced monitoring is contingent on a public water system continuing to experience NO raw or finished water total microcystins detections. Any total microcystins detections during routine (weekly) or reduced sampling will trigger additional sampling. Please refer to the website above for specifics on follow-up sampling requirements.



OH2600111 WAUSEON CITY

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2654220	Facility Name: WAUSEON CITY	
Location	SMP ID: LT2001	Facility Source: Surface Water	Facility Class: CLASS 3

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements
CYANOBACTERIA SCREENING	1 Sample(s) Required between 12/27/2020 and 1/2/2021
	1 Sample(s) Required between 1/10/2021 and 1/16/2021
	1 Sample(s) Required between 1/24/2021 and 1/30/2021
	1 Sample(s) Required between 2/7/2021 and 2/13/2021
	1 Sample(s) Required between 2/21/2021 and 2/27/2021
	1 Sample(s) Required between 3/7/2021 and 3/13/2021
	1 Sample(s) Required between 3/21/2021 and 3/27/2021
	1 Sample(s) Required between 4/4/2021 and 4/10/2021
	1 Sample(s) Required between 4/18/2021 and 4/24/2021
	1 Sample(s) Required between 5/2/2021 and 5/8/2021
	1 Sample(s) Required between 5/16/2021 and 5/22/2021
	1 Sample(s) Required between 5/30/2021 and 6/5/2021
	1 Sample(s) Required between 6/13/2021 and 6/19/2021
	1 Sample(s) Required between 6/27/2021 and 7/3/2021
	1 Sample(s) Required between 7/11/2021 and 7/17/2021
	1 Sample(s) Required between 7/25/2021 and 7/31/2021
	1 Sample(s) Required between 8/8/2021 and 8/14/2021
	1 Sample(s) Required between 8/22/2021 and 8/28/2021
	1 Sample(s) Required between 9/5/2021 and 9/11/2021
	1 Sample(s) Required between 9/19/2021 and 9/25/2021
1 Sample(s) Required between 10/3/2021 and 10/9/2021	
1 Sample(s) Required between 10/17/2021 and 10/23/2021	
1 Sample(s) Required between 10/31/2021 and 11/6/2021	
1 Sample(s) Required between 11/14/2021 and 11/20/2021	
1 Sample(s) Required between 11/28/2021 and 12/4/2021	
1 Sample(s) Required between 12/12/2021 and 12/18/2021	

Cyanobacteria screening sample is to be collected biweekly from raw source water at sample point LT2001 unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at <http://epa.ohio.gov/ddagw/HAB.aspx>. As of 12/31/17, all public water systems are responsible for contracting with a lab certified to perform cyanobacteria screening (qPCR). Please review the website for further information pertaining to follow-up sampling requirements for cyanobacteria screening gene detections, and certified labs that can perform analysis.



OH2600111 WAUSEON CITY

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: WAUSEON CITY DISTRIBUTION SYSTEM	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

ASBESTOS - 1094	Not Required
-----------------	--------------

TOTAL COLIFORM (TCR) - 3100	8 Sample(s) Required between 1/1/2021 and 1/31/2021
	8 Sample(s) Required between 2/1/2021 and 2/28/2021
	8 Sample(s) Required between 3/1/2021 and 3/31/2021
	8 Sample(s) Required between 4/1/2021 and 4/30/2021
	8 Sample(s) Required between 5/1/2021 and 5/31/2021
	8 Sample(s) Required between 6/1/2021 and 6/30/2021
	8 Sample(s) Required between 7/1/2021 and 7/31/2021
	8 Sample(s) Required between 8/1/2021 and 8/31/2021
	8 Sample(s) Required between 9/1/2021 and 9/30/2021
	8 Sample(s) Required between 10/1/2021 and 10/31/2021
	8 Sample(s) Required between 11/1/2021 and 11/30/2021
	8 Sample(s) Required between 12/1/2021 and 12/31/2021

TOTAL CHLORINE - 1000	8 Sample(s) Required between 1/1/2021 and 1/31/2021
	8 Sample(s) Required between 2/1/2021 and 2/28/2021
	8 Sample(s) Required between 3/1/2021 and 3/31/2021
	8 Sample(s) Required between 4/1/2021 and 4/30/2021
	8 Sample(s) Required between 5/1/2021 and 5/31/2021
	8 Sample(s) Required between 6/1/2021 and 6/30/2021
	8 Sample(s) Required between 7/1/2021 and 7/31/2021
	8 Sample(s) Required between 8/1/2021 and 8/31/2021
	8 Sample(s) Required between 9/1/2021 and 9/30/2021
	8 Sample(s) Required between 10/1/2021 and 10/31/2021
	8 Sample(s) Required between 11/1/2021 and 11/30/2021
	8 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: WAUSEON CITY DISTRIBUTION SYSTEM COUNTY RD J GERALD GRAIN	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS201
	Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS201
	Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS201



OH2600111 WAUSEON CITY

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: WAUSEON CITY DISTRIBUTION SYSTEM COUNTY RD J GERALD GRAIN	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 11/8/2021 and 11/14/2021 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: WAUSEON CITY DISTRIBUTION SYSTEM COUNTY PUBLIC WORKS 9306 CO RD 14 HYDRA	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS202

Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS202

Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS202

Dual Sample Required between 11/8/2021 and 11/14/2021 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: WAUSEON CITY DISTRIBUTION SYSTEM Refer to your Lead and Copper plan for SMP IDs	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required



Effective Date: 01/01/2021

2021 ENTRY POINT SCHEDULE

OH2600311 DELTA VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 2662105	Facility Name: DELTA VILLAGE	Facility Class: CLASS 3
	SMP ID: EP002	Facility Source: Surface Water	

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements	
INORGANICS	1 Sample(s) Required between	1/1/2021 and 5/31/2021
<i>Sample for all the analytes listed below:</i>		
ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020		
CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085		
NITRITE - 1041	Not Required	
NITRATE - 1040	1 Sample(s) Required between	1/1/2021 and 1/31/2021
	1 Sample(s) Required between	2/1/2021 and 2/28/2021
	1 Sample(s) Required between	3/1/2021 and 3/31/2021
	1 Sample(s) Required between	4/1/2021 and 4/30/2021
	1 Sample(s) Required between	5/1/2021 and 5/31/2021
	1 Sample(s) Required between	6/1/2021 and 6/30/2021
	1 Sample(s) Required between	7/1/2021 and 7/31/2021
	1 Sample(s) Required between	8/1/2021 and 8/31/2021
	1 Sample(s) Required between	9/1/2021 and 9/30/2021
	1 Sample(s) Required between	10/1/2021 and 10/31/2021
	1 Sample(s) Required between	11/1/2021 and 11/30/2021
	1 Sample(s) Required between	12/1/2021 and 12/31/2021
RADIOLOGICALS	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between	4/1/2021 and 4/30/2021
	1 Sample(s) Required between	5/1/2021 and 5/31/2021
	1 Sample(s) Required between	6/1/2021 and 6/30/2021
<i>Sample for all the analytes listed below:</i>		
ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037		
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between	1/1/2021 and 5/31/2021



OH2600311 DELTA VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2662105	Facility Name: DELTA VILLAGE	
Location	SMP ID: EP002/LT2001	Facility Source: Surface Water	Facility Class: CLASS 3

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements
------------------	--------------------------------

TOTAL MICROCYSTINS	1 Sample Set Required WEEKLY*
--------------------	-------------------------------

Total microcystins sample set refers to one raw source water sample at LT2001 and one finished water sample at EP002. A week is defined as Sunday through Saturday.

**Weekly sampling unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at <http://epa.ohio.gov/ddagw/HAB.aspx>. Reduced monitoring is contingent on a public water system continuing to experience NO raw or finished water total microcystins detections. Any total microcystins detections during routine (weekly) or reduced sampling will trigger additional sampling. Please refer to the website above for specifics on follow-up sampling requirements.*



OH2600311 DELTA VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2662105	Facility Name: DELTA VILLAGE	
Location	SMP ID: LT2001	Facility Source: Surface Water	Facility Class: CLASS 3

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements
------------------	--------------------------------

CYANOBACTERIA SCREENING	1 Sample(s) Required between 12/27/2020 and 1/2/2021
	1 Sample(s) Required between 1/10/2021 and 1/16/2021
	1 Sample(s) Required between 1/24/2021 and 1/30/2021
	1 Sample(s) Required between 2/7/2021 and 2/13/2021
	1 Sample(s) Required between 2/21/2021 and 2/27/2021
	1 Sample(s) Required between 3/7/2021 and 3/13/2021
	1 Sample(s) Required between 3/21/2021 and 3/27/2021
	1 Sample(s) Required between 4/4/2021 and 4/10/2021
	1 Sample(s) Required between 4/18/2021 and 4/24/2021
	1 Sample(s) Required between 5/2/2021 and 5/8/2021
	1 Sample(s) Required between 5/16/2021 and 5/22/2021
	1 Sample(s) Required between 5/30/2021 and 6/5/2021
	1 Sample(s) Required between 6/13/2021 and 6/19/2021
	1 Sample(s) Required between 6/27/2021 and 7/3/2021
	1 Sample(s) Required between 7/11/2021 and 7/17/2021
	1 Sample(s) Required between 7/25/2021 and 7/31/2021
	1 Sample(s) Required between 8/8/2021 and 8/14/2021
	1 Sample(s) Required between 8/22/2021 and 8/28/2021
	1 Sample(s) Required between 9/5/2021 and 9/11/2021
	1 Sample(s) Required between 9/19/2021 and 9/25/2021
1 Sample(s) Required between 10/3/2021 and 10/9/2021	
1 Sample(s) Required between 10/17/2021 and 10/23/2021	
1 Sample(s) Required between 10/31/2021 and 11/6/2021	
1 Sample(s) Required between 11/14/2021 and 11/20/2021	
1 Sample(s) Required between 11/28/2021 and 12/4/2021	
1 Sample(s) Required between 12/12/2021 and 12/18/2021	

Cyanobacteria screening sample is to be collected biweekly from raw source water at sample point LT2001 unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at <http://epa.ohio.gov/ddagw/HAB.aspx>. As of 12/31/17, all public water systems are responsible for contracting with a lab certified to perform cyanobacteria screening (qPCR). Please review the website for further information pertaining to follow-up sampling requirements for cyanobacteria screening gene detections, and certified labs that can perform analysis.

OH2600311 DELTA VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: DELTA VILLAGE DISTRIBUTION SYSTEM	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	4 Sample(s) Required between 1/1/2021 and 1/31/2021
	4 Sample(s) Required between 2/1/2021 and 2/28/2021
	4 Sample(s) Required between 3/1/2021 and 3/31/2021
	4 Sample(s) Required between 4/1/2021 and 4/30/2021
	4 Sample(s) Required between 5/1/2021 and 5/31/2021
	4 Sample(s) Required between 6/1/2021 and 6/30/2021
	4 Sample(s) Required between 7/1/2021 and 7/31/2021
	4 Sample(s) Required between 8/1/2021 and 8/31/2021
	4 Sample(s) Required between 9/1/2021 and 9/30/2021
	4 Sample(s) Required between 10/1/2021 and 10/31/2021
	4 Sample(s) Required between 11/1/2021 and 11/30/2021
	4 Sample(s) Required between 12/1/2021 and 12/31/2021
TOTAL CHLORINE - 1000	4 Sample(s) Required between 1/1/2021 and 1/31/2021
	4 Sample(s) Required between 2/1/2021 and 2/28/2021
	4 Sample(s) Required between 3/1/2021 and 3/31/2021
	4 Sample(s) Required between 4/1/2021 and 4/30/2021
	4 Sample(s) Required between 5/1/2021 and 5/31/2021
	4 Sample(s) Required between 6/1/2021 and 6/30/2021
	4 Sample(s) Required between 7/1/2021 and 7/31/2021
	4 Sample(s) Required between 8/1/2021 and 8/31/2021
	4 Sample(s) Required between 9/1/2021 and 9/30/2021
	4 Sample(s) Required between 10/1/2021 and 10/31/2021
	4 Sample(s) Required between 11/1/2021 and 11/30/2021
	4 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: DELTA VILLAGE DISTRIBUTION SYSTEM CO RD E @ SR 109	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS201
	Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS201
	Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS201
	Dual Sample Required between 11/8/2021 and 11/14/2021 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH2600311 DELTA VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: DELTA VILLAGE DISTRIBUTION SYSTEM 6500 US 20A	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS	Dual Sample Required between 2/8/2021 and 2/14/2021	at: DS202
	Dual Sample Required between 5/8/2021 and 5/14/2021	at: DS202
	Dual Sample Required between 8/8/2021 and 8/14/2021	at: DS202
	Dual Sample Required between 11/8/2021 and 11/14/2021	at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: DELTA VILLAGE DISTRIBUTION SYSTEM Refer to your Lead and Copper plan for SMP IDs	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022	40 Sample(s) Required between 1/1/2021 and 6/30/2021
	40 Sample(s) Required between 7/1/2021 and 12/31/2021

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.



Effective Date: 01/01/2021

2021 ENTRY POINT SCHEDULE

OH2600412 FAYETTE VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 2654223 SMP ID: EP001	Facility Name: FAYETTE VILLAGE Facility Source: Ground Water	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

Chemicals	Monitoring Requirements
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between 1/1/2021 and 5/31/2021
<u>Sample for all the analytes listed below:</u>	
ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037	
VOLATILE ORGANIC CHEMICALS (VOC)	Not Required



OH2600412 FAYETTE VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: FAYETTE, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

ASBESTOS - 1094	Not Required
-----------------	--------------

TOTAL COLIFORM (TCR) - 3100	2 Sample(s) Required between 1/1/2021 and 1/31/2021
	2 Sample(s) Required between 2/1/2021 and 2/28/2021
	2 Sample(s) Required between 3/1/2021 and 3/31/2021
	2 Sample(s) Required between 4/1/2021 and 4/30/2021
	2 Sample(s) Required between 5/1/2021 and 5/31/2021
	2 Sample(s) Required between 6/1/2021 and 6/30/2021
	2 Sample(s) Required between 7/1/2021 and 7/31/2021
	2 Sample(s) Required between 8/1/2021 and 8/31/2021
	2 Sample(s) Required between 9/1/2021 and 9/30/2021
	2 Sample(s) Required between 10/1/2021 and 10/31/2021
	2 Sample(s) Required between 11/1/2021 and 11/30/2021
	2 Sample(s) Required between 12/1/2021 and 12/31/2021

TOTAL CHLORINE - 1000	2 Sample(s) Required between 1/1/2021 and 1/31/2021
	2 Sample(s) Required between 2/1/2021 and 2/28/2021
	2 Sample(s) Required between 3/1/2021 and 3/31/2021
	2 Sample(s) Required between 4/1/2021 and 4/30/2021
	2 Sample(s) Required between 5/1/2021 and 5/31/2021
	2 Sample(s) Required between 6/1/2021 and 6/30/2021
	2 Sample(s) Required between 7/1/2021 and 7/31/2021
	2 Sample(s) Required between 8/1/2021 and 8/31/2021
	2 Sample(s) Required between 9/1/2021 and 9/30/2021
	2 Sample(s) Required between 10/1/2021 and 10/31/2021
	2 Sample(s) Required between 11/1/2021 and 11/30/2021
	2 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: FAYETTE, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	Dual Sample Required between 7/1/2021 and 9/30/2021 at: DS201
-------------------------	---

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2021

2021 DISTRIBUTION SCHEDULE

OH2600412 FAYETTE VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: FAYETTE, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 7/1/2021 and 9/30/2021 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: FAYETTE, VILLAGE OF DISTRIBUTION Refer to your Lead and Copper plan for SMP IDs	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 10 Sample(s) Required between 6/1/2021 and 9/30/2021

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.



OH2600603 LYONS VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: LYONS VILLAGE DISTRIBUTION SYSTEM	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

ASBESTOS - 1094	Not Required
-----------------	--------------

TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 1/31/2021
	1 Sample(s) Required between 2/1/2021 and 2/28/2021
	1 Sample(s) Required between 3/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021
	1 Sample(s) Required between 11/1/2021 and 11/30/2021
	1 Sample(s) Required between 12/1/2021 and 12/31/2021

TOTAL CHLORINE - 1000	1 Sample(s) Required between 1/1/2021 and 1/31/2021
	1 Sample(s) Required between 2/1/2021 and 2/28/2021
	1 Sample(s) Required between 3/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021
	1 Sample(s) Required between 11/1/2021 and 11/30/2021
	1 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: LYONS VILLAGE DISTRIBUTION SYSTEM WATER TOWER ADRIAN ST	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

DISINFECTION BYPRODUCTS	Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS201
	Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS201
	Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS201



OH2600603 LYONS VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: LYONS VILLAGE DISTRIBUTION SYSTEM WATER TOWER ADRIAN ST	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 11/8/2021 and 11/14/2021 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: LYONS VILLAGE DISTRIBUTION SYSTEM PUMP HOUSE CO RD 14	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS202

Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS202

Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS202

Dual Sample Required between 11/8/2021 and 11/14/2021 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: LYONS VILLAGE DISTRIBUTION SYSTEM Refer to your Lead and Copper plan for SMP IDs	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required



OH2601011 SWANTON VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 2654227 SMP ID: EP001	Facility Name: SWANTON VILLAGE Facility Source: Surface Water	Facility Class: CLASS 3
--------------------------	---	--	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

Chemicals	Monitoring Requirements
INORGANICS	1 Sample(s) Required between 1/1/2021 and 5/31/2021
<i>Sample for all the analytes listed below:</i>	
ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085	
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 1/31/2021 1 Sample(s) Required between 2/1/2021 and 2/28/2021 1 Sample(s) Required between 3/1/2021 and 3/31/2021 1 Sample(s) Required between 4/1/2021 and 4/30/2021 1 Sample(s) Required between 5/1/2021 and 5/31/2021 1 Sample(s) Required between 6/1/2021 and 6/30/2021 1 Sample(s) Required between 7/1/2021 and 7/31/2021 1 Sample(s) Required between 8/1/2021 and 8/31/2021 1 Sample(s) Required between 9/1/2021 and 9/30/2021 1 Sample(s) Required between 10/1/2021 and 10/31/2021 1 Sample(s) Required between 11/1/2021 and 11/30/2021 1 Sample(s) Required between 12/1/2021 and 12/31/2021
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between 4/1/2021 and 6/30/2021
<i>Sample for all the analytes listed below:</i>	
ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037	
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 1/1/2021 and 5/31/2021
TOTAL ORGANIC CARBON (TOC)	1 Paired Sample Set Required between 1/1/2021 and 1/31/2021 1 Paired Sample Set Required between 2/1/2021 and 2/28/2021 1 Paired Sample Set Required between 3/1/2021 and 3/31/2021 1 Paired Sample Set Required between 4/1/2021 and 4/30/2021 1 Paired Sample Set Required between 5/1/2021 and 5/31/2021 1 Paired Sample Set Required between 6/1/2021 and 6/30/2021 1 Paired Sample Set Required between 7/1/2021 and 7/31/2021 1 Paired Sample Set Required between 8/1/2021 and 8/31/2021 1 Paired Sample Set Required between 9/1/2021 and 9/30/2021 1 Paired Sample Set Required between 10/1/2021 and 10/31/2021 1 Paired Sample Set Required between 11/1/2021 and 11/30/2021 1 Paired Sample Set Required between 12/1/2021 and 12/31/2021

A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.



OH2601011 SWANTON VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2654227	Facility Name: SWANTON VILLAGE	
Location	SMP ID: EP001/LT2001	Facility Source: Surface Water	Facility Class: CLASS 3

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals

Monitoring Requirements

TOTAL MICROCYSTINS

1 Sample Set Required WEEKLY*

Total microcystins sample set refers to one raw source water sample at LT2001 and one finished water sample at EP001. A week is defined as Sunday through Saturday.

**Weekly sampling unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at <http://epa.ohio.gov/ddagw/HAB.aspx>. Reduced monitoring is contingent on a public water system continuing to experience NO raw or finished water total microcystins detections. Any total microcystins detections during routine (weekly) or reduced sampling will trigger additional sampling. Please refer to the website above for specifics on follow-up sampling requirements.*



OH2601011 SWANTON VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 2654227	Facility Name: SWANTON VILLAGE	
Location	SMP ID: LT2001	Facility Source: Surface Water	Facility Class: CLASS 3

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements
CYANOBACTERIA SCREENING	1 Sample(s) Required between 12/27/2020 and 1/2/2021
	1 Sample(s) Required between 1/10/2021 and 1/16/2021
	1 Sample(s) Required between 1/24/2021 and 1/30/2021
	1 Sample(s) Required between 2/7/2021 and 2/13/2021
	1 Sample(s) Required between 2/21/2021 and 2/27/2021
	1 Sample(s) Required between 3/7/2021 and 3/13/2021
	1 Sample(s) Required between 3/21/2021 and 3/27/2021
	1 Sample(s) Required between 4/4/2021 and 4/10/2021
	1 Sample(s) Required between 4/18/2021 and 4/24/2021
	1 Sample(s) Required between 5/2/2021 and 5/8/2021
	1 Sample(s) Required between 5/16/2021 and 5/22/2021
	1 Sample(s) Required between 5/30/2021 and 6/5/2021
	1 Sample(s) Required between 6/13/2021 and 6/19/2021
	1 Sample(s) Required between 6/27/2021 and 7/3/2021
	1 Sample(s) Required between 7/11/2021 and 7/17/2021
	1 Sample(s) Required between 7/25/2021 and 7/31/2021
	1 Sample(s) Required between 8/8/2021 and 8/14/2021
	1 Sample(s) Required between 8/22/2021 and 8/28/2021
	1 Sample(s) Required between 9/5/2021 and 9/11/2021
	1 Sample(s) Required between 9/19/2021 and 9/25/2021
1 Sample(s) Required between 10/3/2021 and 10/9/2021	
1 Sample(s) Required between 10/17/2021 and 10/23/2021	
1 Sample(s) Required between 10/31/2021 and 11/6/2021	
1 Sample(s) Required between 11/14/2021 and 11/20/2021	
1 Sample(s) Required between 11/28/2021 and 12/4/2021	
1 Sample(s) Required between 12/12/2021 and 12/18/2021	

Cyanobacteria screening sample is to be collected biweekly from raw source water at sample point LT2001 unless requirements for reduced monitoring are met. Current reduced monitoring schedules can be found at <http://epa.ohio.gov/ddagw/HAB.aspx>. As of 12/31/17, all public water systems are responsible for contracting with a lab certified to perform cyanobacteria screening (qPCR). Please review the website for further information pertaining to follow-up sampling requirements for cyanobacteria screening gene detections, and certified labs that can perform analysis.



OH2601011 SWANTON VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: SWANTON VILLAGE DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
ASBESTOS - 1094	Not Required
TOTAL COLIFORM (TCR) - 3100	4 Sample(s) Required between 1/1/2021 and 1/31/2021 4 Sample(s) Required between 2/1/2021 and 2/28/2021 4 Sample(s) Required between 3/1/2021 and 3/31/2021 4 Sample(s) Required between 4/1/2021 and 4/30/2021 4 Sample(s) Required between 5/1/2021 and 5/31/2021 4 Sample(s) Required between 6/1/2021 and 6/30/2021 4 Sample(s) Required between 7/1/2021 and 7/31/2021 4 Sample(s) Required between 8/1/2021 and 8/31/2021 4 Sample(s) Required between 9/1/2021 and 9/30/2021 4 Sample(s) Required between 10/1/2021 and 10/31/2021 4 Sample(s) Required between 11/1/2021 and 11/30/2021 4 Sample(s) Required between 12/1/2021 and 12/31/2021
TOTAL CHLORINE - 1000	4 Sample(s) Required between 1/1/2021 and 1/31/2021 4 Sample(s) Required between 2/1/2021 and 2/28/2021 4 Sample(s) Required between 3/1/2021 and 3/31/2021 4 Sample(s) Required between 4/1/2021 and 4/30/2021 4 Sample(s) Required between 5/1/2021 and 5/31/2021 4 Sample(s) Required between 6/1/2021 and 6/30/2021 4 Sample(s) Required between 7/1/2021 and 7/31/2021 4 Sample(s) Required between 8/1/2021 and 8/31/2021 4 Sample(s) Required between 9/1/2021 and 9/30/2021 4 Sample(s) Required between 10/1/2021 and 10/31/2021 4 Sample(s) Required between 11/1/2021 and 11/30/2021 4 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: SWANTON VILLAGE DISTRIBUTION HYDRANT AT 2173 CO. RD. H	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS201 Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS201 Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS201



OH2601011 SWANTON VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: SWANTON VILLAGE DISTRIBUTION HYDRANT AT 2173 CO. RD. H	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 11/8/2021 and 11/14/2021at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: SWANTON VILLAGE DISTRIBUTION HYDRANT AT 202 CYPRUSS	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 2/8/2021 and 2/14/2021at: DS202

Dual Sample Required between 5/8/2021 and 5/14/2021at: DS202

Dual Sample Required between 8/8/2021 and 8/14/2021at: DS202

Dual Sample Required between 11/8/2021 and 11/14/2021at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: SWANTON VILLAGE DISTRIBUTION Refer to your Lead and Copper plan for SMP IDs	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required



Effective Date: 01/01/2021

2021 ENTRY POINT SCHEDULE

OH2601212 SWANTON MEADOWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 2654228	Facility Name: SWANTON MEADOWS	Facility Class: CLASS A
	SMP ID: EP001	Facility Source: Ground Water	

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

Chemicals	Monitoring Requirements	
INORGANICS	Not Required	
NITRITE - 1041	Not Required	
NITRATE - 1040	1 Sample(s) Required between	10/1/2021 and 12/31/2021
RADIOLOGICALS	1 Sample(s) Required between	1/1/2021 and 3/31/2021
	1 Sample(s) Required between	4/1/2021 and 6/30/2021
	1 Sample(s) Required between	7/1/2021 and 9/30/2021
	1 Sample(s) Required between	10/1/2021 and 12/31/2021
Sample for all the analytes listed below:		
GROSS ALPHA - 4002 RADIUM-228 - 4030		
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between	1/1/2021 and 5/31/2021
Sample for all the analytes listed below:		
ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037		
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between	1/1/2021 and 5/31/2021



OH2601212 SWANTON MEADOWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: **DS1** Facility Name: **SWANTON MEADOWS DISTRIBUTION**
Location SMP ID: **DS000**

Chemicals

Monitoring Requirements

TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between	1/1/2021	and	1/31/2021
	1 Sample(s) Required between	2/1/2021	and	2/28/2021
	1 Sample(s) Required between	3/1/2021	and	3/31/2021
	1 Sample(s) Required between	4/1/2021	and	4/30/2021
	1 Sample(s) Required between	5/1/2021	and	5/31/2021
	1 Sample(s) Required between	6/1/2021	and	6/30/2021
	1 Sample(s) Required between	7/1/2021	and	7/31/2021
	1 Sample(s) Required between	8/1/2021	and	8/31/2021
	1 Sample(s) Required between	9/1/2021	and	9/30/2021
	1 Sample(s) Required between	10/1/2021	and	10/31/2021
	1 Sample(s) Required between	11/1/2021	and	11/30/2021
	1 Sample(s) Required between	12/1/2021	and	12/31/2021

TOTAL CHLORINE - 1000	1 Sample(s) Required between	1/1/2021	and	1/31/2021
	1 Sample(s) Required between	2/1/2021	and	2/28/2021
	1 Sample(s) Required between	3/1/2021	and	3/31/2021
	1 Sample(s) Required between	4/1/2021	and	4/30/2021
	1 Sample(s) Required between	5/1/2021	and	5/31/2021
	1 Sample(s) Required between	6/1/2021	and	6/30/2021
	1 Sample(s) Required between	7/1/2021	and	7/31/2021
	1 Sample(s) Required between	8/1/2021	and	8/31/2021
	1 Sample(s) Required between	9/1/2021	and	9/30/2021
	1 Sample(s) Required between	10/1/2021	and	10/31/2021
	1 Sample(s) Required between	11/1/2021	and	11/30/2021
	1 Sample(s) Required between	12/1/2021	and	12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Facility ID: **DS1** Facility Name: **SWANTON MEADOWS DISTRIBUTION**
Location SMP ID: **DS201** **10487 COUNTY ROAD 4 (LOT #69)**

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS	Dual Sample Required between	7/1/2021	and	9/30/2021	at: DS201
-------------------------	------------------------------	----------	-----	-----------	-----------

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2021

2021 DISTRIBUTION SCHEDULE

OH2601212 SWANTON MEADOWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1	Facility Name: SWANTON MEADOWS DISTRIBUTION
	SMP ID: LC###	Refer to your Lead and Copper plan for SMP IDs

Chemicals	Monitoring Requirements
------------------	--------------------------------

LEAD - 1030 AND COPPER - 1022

Not Required



OH2601403 FULTON/LUCAS WATERLINE

System Type: Nontransient Noncommunity

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: FULTON/LUCAS WATERLINE DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 1/31/2021
	1 Sample(s) Required between 2/1/2021 and 2/28/2021
	1 Sample(s) Required between 3/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021
	1 Sample(s) Required between 11/1/2021 and 11/30/2021
	1 Sample(s) Required between 12/1/2021 and 12/31/2021
TOTAL CHLORINE - 1000	1 Sample(s) Required between 1/1/2021 and 1/31/2021
	1 Sample(s) Required between 2/1/2021 and 2/28/2021
	1 Sample(s) Required between 3/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021
	1 Sample(s) Required between 11/1/2021 and 11/30/2021
	1 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: FULTON/LUCAS WATERLINE DISTRIBUTION 6767 CR 9, DELTA OH	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	Dual Sample Required between 7/1/2021 and 9/30/2021 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 07/16/2021

2021 DISTRIBUTION SCHEDULE

OH2601403 FULTON/LUCAS WATERLINE

System Type: Nontransient Noncommunity

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: FULTON/LUCAS WATERLINE DISTRIBUTION Refer to your Lead and Copper plan for SMP IDs	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

LEAD - 1030 AND COPPER - 1022	10 Sample(s) Required between 7/1/2021 and 12/31/2021
-------------------------------	---

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.



OH2601412 SWANCREEK WATER DISTRICT 1

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

DISTRIBUTION MONITORING SCHEDULE

Table with 2 rows: Sampling Location, Facility ID: DS1, Facility Name: SWANCREEK WATER DISTRICT 1 DISTRIBUTUTIC, SMP ID: DS000

Chemicals Monitoring Requirements

Table with 2 columns: Chemicals (TOTAL COLIFORM (TCR) - 3100), Monitoring Requirements (1 Sample(s) Required between 1/1/2021 and 1/31/2021, etc.)

Table with 2 columns: Chemicals (TOTAL CHLORINE - 1000), Monitoring Requirements (1 Sample(s) Required between 1/1/2021 and 1/31/2021, etc.)

Samples should be collected at the same time and place as the Total Coliform samples.

Table with 2 rows: Sampling Location, Facility ID: DS1, Facility Name: SWANCREEK WATER DISTRICT 1 DISTRIBUTUTIC, SMP ID: DS201, 4549 CO. RD. E DELTA OH

Chemicals Monitoring Requirements

Table with 2 columns: Chemicals (DISINFECTION BYPRODUCTS), Monitoring Requirements (Dual Sample Required between 7/8/2021 and 7/14/2021 at: DS201, etc.)

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) - 2456
2) TTHM - 2950



Effective Date: 09/17/2021

2021 DISTRIBUTION SCHEDULE

OH2601412 SWANCREEK WATER DISTRICT 1

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1	Facility Name: SWANCREEK WATER DISTRICT 1 DISTRIBUTI
	SMP ID: LC###	Refer to your Lead and Copper plan for SMP IDs

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 10 Sample(s) Required between 7/1/2021 and 12/31/2021

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.



OH2601512 SWANCREEK WATER DISTRICT 2

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021

DISTRIBUTION MONITORING SCHEDULE

Table with 4 columns: Sampling Location, Facility ID, Facility Name, Facility Class. Values: DS1, SWAN CREEK WATER DISTRICT 2 DISTRIBUTI, CLASS 1.

Chemicals Monitoring Requirements

Table for TOTAL COLIFORM (TCR) - 3100. Columns: Chemicals, Monitoring Requirements. Lists 12 sampling events from 1/1/2021 to 12/31/2021.

Table for TOTAL CHLORINE - 1000. Columns: Chemicals, Monitoring Requirements. Lists 12 sampling events from 1/1/2021 to 12/31/2021.

Samples should be collected at the same time and place as the Total Coliform samples.

Table with 4 columns: Sampling Location, Facility ID, Facility Name, Facility Class. Values: DS201, 3870 BIRDSONG LANE SWANTON OH, CLASS 1.

Chemicals Monitoring Requirements

Table for DISINFECTION BYPRODUCTS. Columns: Chemicals, Monitoring Requirements. Lists 4 sampling events from 2/1/2021 to 11/7/2021.

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
2) TTHM - 2950



OH2601512 SWANCREEK WATER DISTRICT 2

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: SWAN CREEK WATER DISTRICT 2 DISTRIBUTI 1902 COUNTY RD EF	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS	Dual Sample Required between 2/1/2021 and 2/7/2021	at: DS202
	Dual Sample Required between 5/1/2021 and 5/7/2021	at: DS202
	Dual Sample Required between 8/1/2021 and 8/7/2021	at: DS202
	Dual Sample Required between 11/1/2021 and 11/7/2021	at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: SWAN CREEK WATER DISTRICT 2 DISTRIBUTI Refer to your Lead and Copper plan for SMP IDs	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022	20 Sample(s) Required between 7/1/2021 and 12/31/2021
-------------------------------	---

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.

OH2630812 BRATTON AMLC

System Type: Transient Noncommunity

Operating Period: 7/1 to 10/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378


DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: **DS1** Facility Name: **BRATTON AMLC DISTRIBUTION**
Location SMP ID: **SUP01** Facility Source: **Ground Water**

Chemicals	Monitoring Requirements
TOTAL COLIFORM - SEASONAL STARTUP	At least 1 negative Total Coliform Bacteria sample prior to serving water to the public

*** Seasonal start-up sample does not count for routine compliance requirements. Collect at least one special purpose (SP) sample for total coliform (TC) analysis at the service connection considered to be most susceptible to contamination. The sample must be TC negative before the system may serve water to the public. If the sample is positive, contact your Ohio EPA District Representative for additional requirements. If your start date is different from last year, please contact your Ohio EPA District Representative.***

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2630812 BRATTON AMLC

System Type: Transient Noncommunity

Operating Period: 7/1 to 10/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1 Facility Name: BRATTON AMLC DISTRIBUTION
Location SMP ID: DS000 Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2630812 BRATTON AMLC

System Type: Transient Noncommunity

Operating Period: 7/1 to 10/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654232 Facility Name: BRATTON AMLC
Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 6/1/2021 and 10/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2631212 WHITE CITY RESTAURANT

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: **DS1** Facility Name: **WHITE CITY RESTAURANT**
Location SMP ID: **DS000** Facility Source: **Ground Water**

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2631212 WHITE CITY RESTAURANT

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378


ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654234 Facility Name: WHITE CITY RESTAURANT

Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 3/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2631412 ODNR-HARRISON LAKE ST PK

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378


DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1 Facility Name: ODNR-HARRISON LAKE ST PK DISTRIBUTION
Location SMP ID: SUP01 Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM - SEASONAL STARTUP	At least 1 negative Total Coliform Bacteria sample prior to serving water to the public

*** Seasonal start-up sample does not count for routine compliance requirements. Collect at least one special purpose (SP) sample for total coliform (TC) analysis at the service connection considered to be most susceptible to contamination. The sample must be TC negative before the system may serve water to the public. If the sample is positive, contact your Ohio EPA District Representative for additional requirements. If your start date is different from last year, please contact your Ohio EPA District Representative.***

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2631412 ODNR-HARRISON LAKE ST PK

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1	Facility Name: ODNR-HARRISON LAKE ST PK DISTRIBUTION
Location SMP ID: DS000	Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2631412 ODNR-HARRISON LAKE ST PK

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654236	Facility Name: ODNR HARRISON LAKE ST PK	
Location SMP ID: EP001	Facility Source: Ground Water	Facility Class: CLASS A

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2632212 ARCH MOTEL LLC

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: **DS1** Facility Name: **ARCH MOTEL DISTRIBUTION**
Location SMP ID: **DS000** Facility Source: **Ground Water**

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2632212 ARCH MOTEL LLC

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2662473 Facility Name: ARCH MOTEL 2 - NORTH PLANT
Location SMP ID: EP002 Facility Source:

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 6/1/2021 and 10/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2632212 ARCH MOTEL LLC

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654239 Facility Name: ARCH MOTEL 1 - SOUTH PLANT
Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2632712 4-H CAMP PALMER

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE


Sampling Facility ID: DS1	Facility Name: 4H CAMP PALMER DISTRIBUTION
Location SMP ID: SUP01	Facility Source: Ground Water

Chemicals	Monitoring Requirements
-----------	-------------------------

TOTAL COLIFORM - SEASONAL STARTUP	At least 1 negative Total Coliform Bacteria sample prior to serving water to the public
-----------------------------------	---

*** Seasonal start-up sample does not count for routine compliance requirements. Collect at least one special purpose (SP) sample for total coliform (TC) analysis at the service connection considered to be most susceptible to contamination. The sample must be TC negative before the system may serve water to the public. If the sample is positive, contact your Ohio EPA District Representative for additional requirements. If your start date is different from last year, please contact your Ohio EPA District Representative.***

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2632712 4-H CAMP PALMER

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1 Facility Name: 4H CAMP PALMER DISTRIBUTION
Location SMP ID: DS000 Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 4/26/2021 and 4/30/2021
	1 Sample(s) Required between 5/1/2021 and 5/31/2021
	1 Sample(s) Required between 6/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 7/31/2021
	1 Sample(s) Required between 8/1/2021 and 8/31/2021
	1 Sample(s) Required between 9/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 10/31/2021
	1 Sample(s) Required between 11/1/2021 and 11/15/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2632712 4-H CAMP PALMER

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654240 Facility Name: 4-H CAMP PALMER
Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2633312 OLD PINES GOLF CLUB

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1	Facility Name: OLD PINES GOLF CLUB DISTRIBUTION
Location SMP ID: DS000	Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2633312 OLD PINES GOLF CLUB

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378


ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654243 Facility Name: OLD PINES GOLF CLUB

Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 4/1/2021 and 6/30/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2634312 WEST CLINTON MENNONITE CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: **DS1** Facility Name: **W CLINTON MENNONITE CH. DISTRIBUTION**
Location SMP ID: **DS000** Facility Source: **Ground Water**

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2634312 WEST CLINTON MENNONITE CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654246 Facility Name: W CLINTON MENNONITE CHURCH
Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2634912 HOMESTEAD ICE CREAM SHOPPE

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1	Facility Name: HOMESTEAD ICE CREAM SHOP DISTRIBUTION
Location SMP ID: DS000	Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2634912 HOMESTEAD ICE CREAM SHOPPE

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378


ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654248 Facility Name: HOMESTEAD ICE CREAM SHOPPE

Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2635612 ST LUKE LUTHERAN CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1	Facility Name: ST LUKE LUTHERAN CHURCH DISTRIBUTION
Location SMP ID: DS000	Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2635612 ST LUKE LUTHERAN CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378


ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654250 Facility Name: ST LUKE LUTHERAN CHURCH

Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 3/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2636212 YODER AND FREY, INC.

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: **DS1** Facility Name: **YODER & FREY, INC. DISTRIBUTION**
Location SMP ID: **DS000** Facility Source: **Ground Water**

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2636212 YODER AND FREY, INC.

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378


ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654254 Facility Name: YODER & FREY INC

Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2636912 SHILOH CHRISTIAN UNION CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1	Facility Name: SHILOH CHRIST UN CHURCH DISTRIBUTION
Location SMP ID: DS000	Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2636912 SHILOH CHRISTIAN UNION CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654256	Facility Name: SHILOH CHRIST UN CHURCH
Location SMP ID: EP001	Facility Source: Ground Water
Facility Class: CLASS A	

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2637012 GOOD SHEPD MENNONITE CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1	Facility Name: GOOD SHEPHE MENNONITE CH DISTRIBUTION
Location SMP ID: DS000	Facility Source: Ground Water

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2637012 GOOD SHEPD MENNONITE CHURCH

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2654257 Facility Name: GOOD SHEPHERD MENNONITE CHURCH
Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2637612 US 20 MAIN STOP

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: **DS1** Facility Name: **US 20 MAIN STOP DISTRIBUTION**
Location SMP ID: **DS000** Facility Source: **Ground Water**

Chemicals	Monitoring Requirements
TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

OH2637612 US 20 MAIN STOP

System Type: Transient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.


For water emergencies that occur after hours, please call 800-282-9378

ENTRY POINT MONITORING SCHEDULE

Sampling Facility ID: 2661476 Facility Name: US 20 MAIN STOP
Location SMP ID: EP001 Facility Source: Ground Water

Chemicals	Monitoring Requirements
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 3/31/2021

Where to Collect Samples For a Small Public Water System



Failing to sample for total coliform or nitrate will cost you \$150 or more in penalties for each monitoring violation. A list of drinking water sample collection services that can assist you with collecting water samples is located at: <http://epa.ohio.gov/portals/28/documents/PWS/DWSample.pdf>.

Save a dime. Sample on time!

**OH2637812 NORTHEAST WATER SYSTEM**

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.
Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1	Facility Name: NORTHEAST WATER SYSTEM DISTRIBUTION	Facility Class: CLASS 1
	SMP ID: DS000		

Chemicals	Monitoring Requirements
ASBESTOS - 1094	Not Required
TOTAL COLIFORM (TCR) - 3100	2 Sample(s) Required between 1/1/2021 and 1/31/2021 2 Sample(s) Required between 2/1/2021 and 2/28/2021 2 Sample(s) Required between 3/1/2021 and 3/31/2021 2 Sample(s) Required between 4/1/2021 and 4/30/2021 2 Sample(s) Required between 5/1/2021 and 5/31/2021 2 Sample(s) Required between 6/1/2021 and 6/30/2021 2 Sample(s) Required between 7/1/2021 and 7/31/2021 2 Sample(s) Required between 8/1/2021 and 8/31/2021 2 Sample(s) Required between 9/1/2021 and 9/30/2021 2 Sample(s) Required between 10/1/2021 and 10/31/2021 2 Sample(s) Required between 11/1/2021 and 11/30/2021 2 Sample(s) Required between 12/1/2021 and 12/31/2021
TOTAL CHLORINE - 1000	2 Sample(s) Required between 1/1/2021 and 1/31/2021 2 Sample(s) Required between 2/1/2021 and 2/28/2021 2 Sample(s) Required between 3/1/2021 and 3/31/2021 2 Sample(s) Required between 4/1/2021 and 4/30/2021 2 Sample(s) Required between 5/1/2021 and 5/31/2021 2 Sample(s) Required between 6/1/2021 and 6/30/2021 2 Sample(s) Required between 7/1/2021 and 7/31/2021 2 Sample(s) Required between 8/1/2021 and 8/31/2021 2 Sample(s) Required between 9/1/2021 and 9/30/2021 2 Sample(s) Required between 10/1/2021 and 10/31/2021 2 Sample(s) Required between 11/1/2021 and 11/30/2021 2 Sample(s) Required between 12/1/2021 and 12/31/2021

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1	Facility Name: NORTHEAST WATER SYSTEM DISTRIBUTION	Facility Class: CLASS 1
	SMP ID: DS201	8871 STATE HIGHWAY 120	

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS201 Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS201 Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS201



OH2637812 NORTHEAST WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2021**

DISTRIBUTION MONITORING SCHEDULE

Sampling Facility ID: DS1 Facility Name: NORTHEAST WATER SYSTEM DISTRIBUTION Facility Class: CLASS 1
Location SMP ID: DS201 8871 STATE HIGHWAY 120

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 11/8/2021 and 11/14/2021 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Facility ID: DS1 Facility Name: NORTHEAST WATER SYSTEM DISTRIBUTION Facility Class: CLASS 1
Location SMP ID: DS202 251 MILL ST

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 2/8/2021 and 2/14/2021 at: DS202

Dual Sample Required between 5/8/2021 and 5/14/2021 at: DS202

Dual Sample Required between 8/8/2021 and 8/14/2021 at: DS202

Dual Sample Required between 11/8/2021 and 11/14/2021 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Facility ID: DS1 Facility Name: NORTHEAST WATER SYSTEM DISTRIBUTION Facility Class: CLASS 1
Location SMP ID: LC### Refer to your Lead and Copper plan for SMP IDs

Chemicals

Monitoring Requirements

LEAD - 1030 AND COPPER - 1022

20 Sample(s) Required between 7/1/2021 and 12/31/2021

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.



Effective Date: 01/01/2021

2021 ENTRY POINT SCHEDULE

OH2637912 TRI-COUNTY BLOCK AND BRICK

System Type: Nontransient Noncommunity

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 2662470	Facility Name: TRI-COUNTY BLOCK AND BRICK INC	Facility Class: CLASS A
	SMP ID: EP001	Facility Source: Ground Water	

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Monitoring Requirements
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2021 and 5/31/2021
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between 1/1/2021 and 5/31/2021
<u>Sample for all the analytes listed below:</u>	
ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037	
VOLATILE ORGANIC CHEMICALS (VOC)	Not Required



OH2637912 TRI-COUNTY BLOCK AND BRICK

System Type: Nontransient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: TRI-COUNTY BLOCK AND BRICK DISTRIBUTIC
--------------------------	---	--

Chemicals Monitoring Requirements

TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2021 and 3/31/2021
	1 Sample(s) Required between 4/1/2021 and 6/30/2021
	1 Sample(s) Required between 7/1/2021 and 9/30/2021
	1 Sample(s) Required between 10/1/2021 and 12/31/2021

Sampling Location	Facility ID: DS1 SMP ID: LC###	Facility Name: TRI-COUNTY BLOCK AND BRICK DISTRIBUTIC Refer to your Lead and Copper plan for SMP IDs
--------------------------	---	---

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022	5 Sample(s) Required between 6/1/2021 and 9/30/2021
-------------------------------	---

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Lead and copper sample monitoring point (SMP) IDs (LC###) must be current and reflect properly tiered sites according to OAC Rule 3745-81-86. Submit lead and copper SMP ID revisions to your Ohio EPA District Office. Forms and templates are available online at <http://epa.ohio.gov/ddagw/pws/leadandcopper.aspx>. For questions contact your Ohio EPA District Office representative.



Effective Date: 01/01/2021

2021 DISTRIBUTION SCHEDULE

OH2637913 GH & A-BRICK RECLAMATION YARD

System Type: Nontransient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Minimal Treatment System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling	Facility ID: DS1	Facility Name: DISTRIBUTION
Location	SMP ID: LC###	Refer to your Lead and Copper plan for SMP IDs

Chemicals	Monitoring Requirements
LEAD - 1030 AND COPPER - 1022	Not Required