

ATTACHMENT II

Table - Final Outfall - 1PT00083001

Effluent Characteristic	Discharge Limitations							Monitoring Requirements		
Parameter	Concentration specified Units					Loadings* kg/day		Measuring Frequency	Sampling Type	Monitoring Month
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Week	Grab	All
00056 - Flow Rate - GPD	-	-	-	-	-	-	-	1/Day	Estimate	All
00083 - Color, Severity - Units	-	-	-	-	-	-	-	1/Day	Estimate	All
00300- Dissolved Oxygen - mg/l	-	-	-	-	-	-	-	1/Week	Grab	All
00530 - Total Suspended Solids mg/l	-	-	45.0	30.0	-	2.2	1.5	1/Month	Grab	All
00610 - Nitrogen, Ammonia - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
01330 - Odor, Severity - Units	-	-	-	-	-	-	-	1/Day	Estimate	All
01350 - Turbidity, Severity - Units	-	-	-	-	-	-	-	1/Day	Estimate	All
31616 - Fecal Coliform - #/100 ml	-	-	1000	2000	-	-	-	1/Month	Grab	Summer
50060 - Chlorine, TR - mg/l								1/2Weeks	Grab	Summer
80082 - CBOD _{5-day} - mg/l	-	-	40.0	25.0	-	1.9	1.2	1/Month	Grab	All

* Effluent loadings based on average design flow of 0.013 MGD